

IPG750

GENERATING SET MODEL			
Output Ratings	Prime	Standby	
380-415 V, 3 ph, 50 Hz, 1500 rpm	750 KVA / 600 KW	825 KVA / 660 KW	
480 V, 3 ph, 60 Hz, 1800 rpm	750 KVA / 600 KW	825 KVA / 660 KW	
Applicable Voltages: 220/127 V at 60 Hz only (Consult your dealer for more details)		Ratings at 0.8 Power Factor	

ENGINE / TECHNICAL DATA				
Engine Make	Perkins			
Engine Model	4006 - 23TAG2A			
Governing Type	Digital			
Number of Cylinders	6			
Cylinder Arrangement	Vertical in line			
Bore and Stroke mm	160 x 190			
Displacement / Cubic Capacity litres	22.921			
Induction System	Turbocharged and air to air charge cooled			
Cycle	4 stroke			
Combustion System	Direct Injection			
Compression Ratio	13.6:1			
Rotation	Anti-clockwise, viewed on flywheel			
Cooling System	Water - cooled			
Frequency and Engine Speed	50Hz & 1500rpm 60Hz & 1800rpm		200rnm	
Trequency and Engine Speed	טחב מ ו	Soorbill	00112 α 1	ooorpiii
Trequency and Engine Speed	Prime	Standby		Standby
Gross Engine Power kW (hp)	Prime		Prime	
	Prime	Standby	Prime	Standby
Gross Engine Power kW (hp)	Prime 658(882)	Standby	Prime 684(917)	Standby
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr	Prime 658(882) 83	Standby	Prime 684(917) 90	Standby
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr	Prime 658(882) 83 121	721(967) -	Prime 684(917) 90 129	759(1018) -
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr @ 100% load L/hr	Prime 658(882) 83 121 157	Standby 721(967) 173	Prime 684(917) 90 129 177	Standby 759(1018) 199
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr @ 100% load L/hr Total Lubrication System Capacity litres	Prime 658(882) 83 121 157 113.4	Standby 721(967) - 173 113.4	Prime 684(917) 90 129 177 113.4	759(1018) - 199 113.4
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr @ 100% load L/hr Total Lubrication System Capacity litres Total Coolant Capacity litres	Prime 658(882) 83 121 157 113.4 105	Standby 721(967) 173 113.4 105	Prime 684(917) 90 129 177 113.4 105	759(1018) - - 199 113.4 105
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr @ 100% load L/hr Total Lubrication System Capacity litres Total Coolant Capacity litres Exhaust Temperature: °C	Prime 658(882) 83 121 157 113.4 105 430	Standby 721(967) - 173 113.4 105 430	Prime 684(917) 90 129 177 113.4 105 430	759(1018) - - 199 113.4 105 430
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr @ 100% load L/hr Total Lubrication System Capacity litres Total Coolant Capacity litres Exhaust Temperature: °C Radiator Cooling Air Flow (Min): m³/sec	Prime 658(882) 83 121 157 113.4 105 430 20	Standby 721(967) - 173 113.4 105 430 20	Prime 684(917) 90 129 177 113.4 105 430 22	759(1018) - 199 113.4 105 430 22
Gross Engine Power kW (hp) Fuel Consumption @ 50% load L/hr @ 75% load L/hr @ 100% load L/hr Total Lubrication System Capacity litres Total Coolant Capacity litres Exhaust Temperature: °C Radiator Cooling Air Flow (Min): m³/sec Combustion Air Flow: m³/min	Prime 658(882) 83 121 157 113.4 105 430 20 64	Standby 721(967) - 173 113.4 105 430 20 71	Prime 684(917) 90 129 177 113.4 105 430 22 65	Standby 759(1018) 199 113.4 105 430 22 72



The set picture may include optional accessories

DIMENSIONS AND WEIGHT			
Length cm	Width cm	Height cm	Weight*kg (wet)
430	174	215	6370

* For skid mounted genset without enclosure wet weight = with lube oil and coolant

ALTERNATOR DATA	
Make	Leroy Somer
Model	LSA49.1M75
No. of bearings	1
Insulation class	Н
Total Harmonic Content	<4%
Wires	6
Ingress Protection	IP23
Excitation System	AREP
Winding Pitch	2/3 (n° 6S)
AVR Model	R450
Overspeed	2250 mn ⁻¹
Voltage Regulation (steady)	± 0.5%
Short Circuit Capacity	300% (3 ln):10s
PMG Excitation System Available as Optional.	





IPG750

CONTROL PANEL

Make	Deep Sea
Model	DSE7320

DSE7320 is an Auto Mains (Utility) Failure Control Module. It is operated via the START, STOP, AUTO and MANUAL soft touch membrane buttons on the front panel. DSE7320 can be controlled remotely using either a GSM Modem, Ethernet via DSE860/865 or via RS485.

Protection:

- Fail to start
- Low oil pressure
- · High engine temperature
- U/O Voltage shutdown
- U/O Frequency shutdown
- Underspeed, Overspeed
- Loss of engine speed detection
- · High/Low battery voltage
- kW overload
- Unbalanced load
- Low fuel alarm (if fitted)
- Battery charger failure (if fitted)

RATINGS DEFINITION

Prime Power

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. 10% overload power is available for 1 hour in 12 hours continuous operation.

Standby Power

These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings.

STANDARD REFERENCE CONDITIONS

Output ratings are presented at 25°C air inlet temperature, barometric pressure 100 kPa, relative humidity 30%. This generating set is designed to operate at high ambient temperatures (up to 55°C), humidity (up to 99%) and higher altitudes. De-ration may apply, please consult your dealer for specific site ratings.

Some of the specifications are not standard on all Genset models.



The set picture may include optional accessories

AVAILABLE OPTIONS & ACCESSORIES

We offer a range of optional features and accessories to tailor our generating sets to meet your power needs.

OPTIONS

- A variety of generating set control and synchronizing panels
- Additional protection alarms and shutdowns
- Water fuel seperator
- Water jacket heater
- · Battery charger

ACCESSORIES

- Genuine spare parts
- Load banks
- Auxiliary fuel tanks
- Manual & automatic transfer switches

STANDARD SPECIFICATIONS

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine.

2. ENGINE FILTRATION SYSTEM

- Two Cartridge type dry air filters.
- Cartridge type fuel filter.
- Three Full flow lube oil filters.

All filters have replaceable elements.

3. TROPICAL COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors).





IPG750

STANDARD SPECIFICATIONS

4. EXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer.

Silencer noise reduction level 14 (dB)
Maximum allowable back pressure 6.0 (kPa)

5. CIRCUIT BREAKER TYPE

ABB 3 pole MCB. (4 pole is optional).

6. FUEL SYSTEM

On Generating Sets up to 700 kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

7. ALTERNATOR

7.1 INSULATION SYSTEM

- The insulation system is Class H.
- All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin.
- Heavy coat of antitracking varnish additional protection against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at $\pm 0.5\%$. Nominal adjustment by means of a trim pot incorporated on the AVR.

7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the Full Load impedance at zero Power Factor can be sustained for 10 seconds.

8. MOUNTING ARRANGEMENT

8.1 BASE FRAME

The complete Generating Set is mounted as a whole on a heavy duty fabricated steel Baseframe.

8.2 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.3 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.4 SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

9. FACTORY TESTS

- The Generating set is load tested before dispatch
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATIONS

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDE0530. NEMA MG 1.22 and ISO 8528.

13. WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months. Warranty of the equipment is in line with manufacturers warranty terms & conditions.

In line with continuous product development, we reserve the right to change specifications without notice.

DISTRIBUTED AND SERVICED BY:



M&H ENGINEERING LTD

Coastal Estate Junction - Spintex Road | P.O. Box KA16128 | Accra - Ghana Phone: +233 302 810 552 | Mobiles: +233 244 454 597 +233 548 151 515 Email: info@mhengltd.com | Website: www.mhengltd.com